



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/08/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 11 b/d	tripped on mpcb due to material jamming at ducksheets and returnidlers	mpcb made on and inform to operation	06:30:00	06:40:00	
2	OHP	co 87	reported red/tharmal olr got short and power contactor stuckup	olr and power contactor 3tf 50 replaced then control tested ok clearance given to ope.	09:30:00	11:35:00	motor megger values are phase to earth 200 mega omes at motor tb
3	OHP	wobr on co 29	luffing not taking place	didnt found any elect. problem	08:00:00	08:15:00	oil leakage at hydro.pump
4	OHP	co 21	operation request brs to be kept in ckt.	kept in ckt.	13:00:00	13:05:00	
5	OHP	co 29	tripped on olr	reset done	11:00:00	11:30:00	
6	OHP	rsc0 10a c/d	tripped on mpcb due to track jamming	mpcb made on	12:00:00	12:30:00	
7	CHP	cc 51	tripped on MPD/feeding conver stopped 5 times	reset done	06:00:00	06:20:00	6.00 am to 1020 am
8	CHP	cc 114	tripped on olr	reset done	09:00:00	09:15:00	
9	CHP	cc 54	tripped on olr	reset done 2 times	06:46:00	06:50:00	
10	CHP	scr 5 on cc32	It not taking place tension acted	pcrd cable tension release	06:37:00	06:47:00	
11	CHP	scr 2 on cc34	It not taking place/m7 olr acted due track jamming	reset done	06:43:00	07:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/08/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	scr 8 on cc111	bc not running/tripped on olr	reset done	06:47:00	07:05:00	
13	CHP	cc35	tripped on olr	reset done	09:40:00	09:50:00	
14	CHP	cc 35	reported red/checked and found motor got burnt	in form to g shift	08:00:00	08:50:00	motor to changed
15	CHP	cc 32	brs acted	reset done	08:44:00	08:51:00	
16	CHP	scr 9 on cc 104slewing not taking place	limit acted	limit released then ok	09:00:00	09:10:00	
17	CHP	cc 31	bc tripped on olr	reset done	10:00:00	11:10:00	
18	CHP	scr 6 on cc38	tul not working due to rust rejoined	but not working/ ope.request frobypass/bypass done after shift end kept in ckt	11:28:00	14:00:00	
19	CHP	scr3 on cc40	lt not taking place/drive tripped	reset done	13:00:00	13:10:00	
20	CHP	s3 on cc112	lt not taking place/mechanical guide problem	pcrd drum tied with rope and inform to mechanical	12:50:00	13:00:00	
21	CHP	scr 7 oncc105	lt not taking place/track jamming	inform to operation to cleare the material	12:10:00	12:20:00	
22	WT	op 2	pusher not moving/ ACB tripped due to bottom pad jumpers got cut at cl no.8 and 9	bottom collector jumper replaced and acb made on then tested ok	12:30:00	13:15:00	
23	WT	ot 4	drive 2 tripped on pgf fault	reset done	11:30:00	11:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/08/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
24	WT	oc1a	zss acteing/cable got cut for cjb to zss module and glass fuse blown	cable rejoined and fuse replaced	12:45:00	13:10:00	while cleaning