



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/01/2026

Area: IOSA

| Equipment | Job |
|-------------------|---|
| 1-142LC-2 | HOUSE KEEPING DONE FOR LC-2 FIRST FLOOR AND GROUND FLOOR. |
| BLENDER RECLAIMER | FAN COVER MESH PROVIDED FOR AIR BLAST COOLER. |
| OC-13A MOTOR | REPLACED DAMAGED FAN COVER MESH. |
| OC-7C | CONVEYOR GALLERY TAIL END SIDE LIGHTING DEFECTS RECTIFIED AND SUFFICIENT LIGHTING PROVIDED. |
| OC-7B | CONVEYOR GALLERY TAIL END SIDE LIGHTING DEFECTS RECTIFIED AND SUFFICIENT LIGHTING PROVIDED. |
| WOBR-LnT | PPM DONE ON MOTORS, FIELD DEVICES AND PANELS. TRIAL RUN TAKEN AFTER PPM AND CHECKED ALL FEEDBACK. |
| OJH-8A | PPM DONE ON MOTOR AND PANEL OF HOIST. |