



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 02/05/2025

Area: WT

Equipment	Job
AF 3(O)	local Inch start push button replaced
OT 5	out haul side lighting ,circuit problem rectified and kept in timer circuit
	lighting problem rectified 3 nos 150W SV and 1no 35W LED replaced
CP 4	
OP 3	D4 one lug found cut in motor TB ,replaced and 1no top jumper replaced
	after rake maintenance done

CO 5,6 &7 tunnel

OP 2,3,4,5,6,7 &10