



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 24	LT NOT TAKING PLACE DRIVE TRIP	RESET	23:00:00	23:10:00	
2	OHP	WOBR ON CO 29	B/W MPCB TRIP	RESET	02:10:00	02:20:00	
3	OHP	CO 35	OLR ACTED	RESET	01:05:00	01:10:00	
4	OHP	CO 32	OLR ACTED	RESET	02:25:00	02:35:00	
5	OHP	CO 29	OLR ACTED	RESET	02:50:00	03:00:00	
6	OHP	CO 26	OLR ACTED (2TIMES)	RESET	03:00:00	03:15:00	
7	CHP	CC 35 SCR 1	B/C not running, wrong complaint	checked found all ok	22:30:00	22:45:00	
8	CHP	CC 34 SCR 2	LT not working, wrong complaint	checked both FWD and REV LT ok	23:00:00	23:15:00	
9	CHP	CC 105 SCR 10	signal missing	LT done FWD, than ok	23:55:00	00:05:00	
10	CHP	CC 125	OLR acted	reset	01:30:00	01:38:00	
11	CHP	CC 36 SCR 7	LT not working, OT acted	OT released	01:40:00	01:55:00	
12	CHP	CC 35 SCR 1	LUFF not working, olr acted	reset	02:30:00	02:45:00	
13	CHP	CC 32 SCR 5	lighting not working, e/f in control transformer	fault isolated , MCB made on	04:40:00	04:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 105 SCR 10	signal missing	LT done than ok	05:15:00	05:25:00	
15	CHP	CC 32 SCR 5	BC not running, CJS acted, full jamming	informed operation	04:30:00	04:40:00	
16	CHP	CC 26 F/G	OLR ACTED	RESET	00:20:00	00:30:00	
17	CHP	cc 131	OLR ACTED	reset	01:50:00	01:55:00	3 times
18	CHP	CC 117	olr acted	reset	23:25:00	23:40:00	
19	CHP	CC 54	OLR acted	reset	00:20:00	00:25:00	3 times