



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/09/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-111 B/D	OLR ACTED (2TIMES)	RESET DONE	08:30:00	08:50:00	
2	OHP	TBS ON CO-22	L/LUFF NOT WORKING CHECKED AND FOUND CONTROL MCB TRIP	MADE ON THAN OK	07:00:00	07:15:00	
3	OHP	BRC ON CO-30	LT NOT TAKING PLACE SKEW ACTED	SKEW ADJUSTED WITH MECHANICAL	10:00:00	10:30:00	
4	OHP	BRC ON CO-30	B/C STOPPING FREQUENTLY CHECKED AND FOUND E/STOP WIRE OPEN	E/STOP WIRE CONNECTED THAN OK	12:45:00	13:00:00	
5	OHP	RSCO-6A (C/D)	OLR ACTED	RESET DONE	13:15:00	13:25:00	
6	OHP	CC-36 SCR-1	LUFF NOT WORKING CHECKED AND FOUND LOWER LIMIT ACTED	LIMIT BY PASSED OPERATION REQUIREMENT	08:05:00	08:15:00	
7	CHP	CC-33 R-1	B/C OLR ACTED	RESET DONE	06:40:00	06:55:00	
8	CHP	CC-33 R-1	LUFF NOT WORKING FOUND OIL LOW LEVEL INFORMED TO MECHANICAL	TOPUP THE OIL THAN OK	08:30:00	08:45:00	
9	CHP	CC-51	FEEDING CONVEYOR MPD TRIP (2TIMES)	RESET DONE	07:30:00	07:45:00	
10	WT	OC-1A	STOPPING ON ZSS CHECKED AND FOUND ZSS PROBE NOT SENSING	ZSS PROBE GAP ADJUSTED AND PROBE FIXING PROPERLY THANOK	07:15:00	07:25:00	