



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/12/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	02:50:00	03:00:00	
2	OHP	CO-85	Reported tripped	OLR acted.Reset done	02:45:00	02:50:00	
3	OHP	CO-26	Reported tripped	OLR acted.Reset done(3 times)	22:10:00	05:25:00	
4	OHP	CO-10A	Reported ZSS acting	Checked and found Probe insulation damaged.Insulated properly and tested okay	00:40:00	01:00:00	
5	OHP	Cr-2A	Reported ZSS acting	Probe gap adjusted and tested okay	04:30:00	05:00:00	
6	CHP	Cc-15	Reported ZSS acting	Belt through cut found.	05:00:00	05:10:00	Informed to operation
7	WT	OP-9	Emergency acted at Dead end	Released and tested okay	22:35:00	22:50:00	
8	IOSA	BRC	Reported CT not taking place	Ct limit handle damaged.handle replaced and tested okay	01:35:00	01:50:00	