



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|---|----------|----------|---|
| 1 | OHP | BRC on Co 28 | b/w not rotating, control mcb is in off condition | made on | 06:20:00 | 06:35:00 | |
| 2 | OHP | CO 26 | olr acted | reset | 09:15:00 | 09:25:00 | |
| 3 | OHP | TBS on Co 7A | luffing not working, up limit stucked | limit released | 08:50:00 | 09:05:00 | |
| 4 | OHP | WOBR on co 25 | luff down ok, up not working, solenoid not picked up 12 v voltage | all control wire checked and tightened, finally 24 v came | 08:15:00 | 08:45:00 | no delay, talk to operator tell them to convey when up required we will do manually |
| 5 | OHP | CO 19 | zss acted, probe wire got cut | jointed | 07:45:00 | 07:56:00 | |
| 6 | OHP | CR 1A | not running, filter clogged problem | bypassed as per operation instruction | 08:00:00 | 08:15:00 | |
| 7 | OHP | co 50 | olr acted | reset | 06:15:00 | 06:25:00 | |
| 8 | CHP | CC 117 | olr acted 4 times | reset | 08:20:00 | 12:30:00 | |
| 9 | CHP | CC 51 | mpd tripped 5 times | reset | 08:00:00 | 13:45:00 | |
| 10 | CHP | CC 54 | olr acted 5 times | reset | 10:30:00 | 13:45:00 | |
| 11 | CHP | CC 131 | olr acted | reset | 07:20:00 | 07:25:00 | |
| 12 | CHP | CC 104 scr9 | slew not working, mpcb tripped | made it on | 07:30:00 | 07:45:00 | |
| 13 | CHP | cc 40 SCR2 | slew not working, jamming | informed operation | 08:59:00 | 09:10:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|---------|----------|----------|---------|
| 14 | CHP | CC 31 SCR4 | operator cabin side no lighting, mcb tripped | made on | 11:30:00 | 11:40:00 | |