



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/12/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-28	P/C cable got cut	Cable rejoin done and kept in line	14:50:00	15:10:00	
2	OHP	CO-33M	Reported tripped	OLR acted.Reset done(2 times)	15:30:00 16:00:00	15:35:00 16:05:00	
3	OHP	BRC on CO-28	CT not taking place	S/S in local.Kept in Auto	15:00:00	15:10:00	
4	OHP	CO-26	Reported tripped	OLR acted.Reset done	16:15:00	16:20:00	
5	OHP	CO-84	Reported tripped	OLR acted.Reset done(2 times)	19:15:00	20:25:00	
6	OHP	TBS on CO-22	No drives working	Control made on and tested okay	19:45:00	20:00:00	
7	CHP	CC 40 SCR-2	Signal missing	Modem cleaning done and Lt forward done and tested okay	15:10:00	15:30:00	Delay increased in program
8	CHP	Cc 39 SCR-6	B/C not running	OLR acted.Reset done	16:50:00	17:10:00	
9	CHP	CC 34 SCR-1	Luffing down not taking place when up limit acted	Program modified and tested okay	21:00:00	21:30:00	No delay
10	CHP	Cc-54	Reported tripped	OLR acted.Reset done(8 times)	17:00:00	19:30:00	
11	CHP	Cc 114	Reported tripped	OLR acted.Reset done	20:05:00	20:15:00	
12	CHP	CC 114	Stopped on ZSS	Due to OLR acted.Reset done	20:15:00	20:20:00	
13	IOSA	BRC	CT end emergency acted	Mains made on and tested okay	15:05:00	15:20:00	