



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/07/2025

Area: OHP

| Equipment | Job |
|------------|---|
| lc5 to om9 | profibus spare cable is terminated, and restored communication. |