



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/06/2025

Area: IOSA

Equipment	Job
OTT-1A	PPM DONE ON MOTOR , PANEL AND FIELD DEVICES
OC-33A CARRIAGE	PPM DONE ON MOTOR AND FIELD DEVICES.
OC-33A CONVEYOR	PPM DONE ON MOTOR AND FIELD DEVICES.
BRC	LOOP GIVEN FOR TERMINAL RE-LUGGING IN SLIPRING BOX. HT CABLE UN-WOUND AND WOUNDED.