



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/12/2025

Shift: B

Incharge(s): Amit Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|---|----------------------|----------------------|----------------------------|
| 1 | OHP | CO-28 | P/C cable got cut | Cable rejoin done and kept in line | 14:50:00 | 15:10:00 | |
| 2 | OHP | CO-33M | Reported tripped | OLR acted.Reset done(2 times) | 15:30:00 16:00:00 | 15:35:00 16:05:00 | |
| 3 | OHP | BRC on CO-28 | CT not taking place | S/S in local.Kept in Auto | 15:00:00 | 15:10:00 | |
| 4 | OHP | CO-26 | Reported tripped | OLR acted.Reset done | 16:15:00 | 16:20:00 | |
| 5 | OHP | CO-84 | Reported tripped | OLR acted.Reset done(2 times) | 19:15:00 | 20:25:00 | |
| 6 | OHP | TBS on CO-22 | No drives working | Control made on and tested okay | 19:45:00 | 20:00:00 | |
| 7 | CHP | CC 40 SCR-2 | Signal missing | Modem cleaning done and Lt forward done and tested okay | 15:10:00 | 15:30:00 | Delay increased in program |
| 8 | CHP | Cc 39 SCR-6 | B/C not running | OLR acted.Reset done | 16:50:00 | 17:10:00 | |
| 9 | CHP | CC 34 SCR-1 | Luffing down not taking place when up limit acted | Program modified and tested okay | 21:00:00 | 21:30:00 | No delay |
| 10 | CHP | Cc-54 | Reported tripped | OLR acted.Reset done(8 times) | 17:00:00 | 19:30:00 | |
| 11 | CHP | Cc 114 | Reported tripped | OLR acted.Reset done | 20:05:00 | 20:15:00 | |
| 12 | CHP | CC 114 | Stopped on ZSS | Due to OLR acted.Reset done | 20:15:00 | 20:20:00 | |
| 13 | IOSA | BRC | CT end emergency acted | Mains made on and tested okay | 15:05:00 | 15:20:00 | |