



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/01/2026

Area: CHP

| Equipment | Job |
|---------------------|---|
| All yard machines | Lighting inspection was done |
| CC 112,111,31,32,33 | HT coupler space heaters inspected and rectified ckt problems |
| CC 52 | Defective drive removed and shifted to CM 18 |
| CC 213 | Lighting power restored |
| CC 41/43 tunnel | 6 nos 30W LED lamps replaced |
| CC 107 | Running inspection and vibration readings noted |
| LC 6 | I/C-1 charged and found after sometime HT tripped. Informed DNW |