



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/12/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment    | Problem                                      | Action              | From     | To       | Remarks |
|-------|------|--------------|--|---------------------|----------|----------|---------|
| 1     | OHP  | BRC on co 31 | b/c olr acted                                | reset               | 16:00:00 | 16:15:00 |         |
| 2     | OHP  | CR 1         | MPR tripped                                  | reset               | 17:30:00 | 17:40:00 | 2 times |
| 3     | OHP  | CO 26        | OLr acted                                    | reset               | 20:50:00 | 20:58:00 |         |
| 4     | OHP  | CO 77        | olr acted                                    | reset               | 19:40:00 | 19:50:00 |         |
| 5     | OHP  | co 31        | bw 2 not running,olr acted                   | reset               | 21:50:00 | 22:00:00 |         |
| 6     | CHP  | cc 31 scr4   | LT not working,Ot acted,PCRD cable fell down | pcrd winding done   | 14:40:00 | 15:00:00 |         |
| 7     | CHP  | CC 32        | olr acted                                    | reset               | 15:20:00 | 15:30:00 |         |
| 8     | CHP  | CC 35 SCR3   | b/c not running,zss cage problem,            | cage fixed properly | 15:40:00 | 16:00:00 |         |
| 9     | CHP  | CC 33 R1     | b/c not running,zss cage stone stucked       | removed             | 17:45:00 | 18:00:00 |         |
| 10    | CHP  | CC 50        | ZSS acted, sensor cable loose connection     | tightened           | 20:30:00 | 20:40:00 |         |
| 11    | CHP  | CC 54        | olr acted                                    | reset               | 17:40:00 | 17:45:00 |         |