



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 76R	OLR ACTED	RESET	14:30:00	14:40:00	
2	OHP	CO 11(C) DRIVE	OLR ACTED	RESET	14:40:00	14:50:00	
3	OHP	CO76R	ZS PROBE DAMAGED	ZS BYPASSED	15:00:00	15:20:00	
4	OHP	WOBR ON CO 26	LT NOT TAKING PLACE O/T ACTED	RELEASED AND PCRD CABLE PROPER WINDING WAS DONE	16:30:00	17:00:00	
5	OHP	WOBR ON CO 26	SLEW NOT TAKING PLACE DRIVE TRIP	RESET	17:30:00	17:40:00	
6	OHP	WOBR ON CO 25	SLEW NOT MOVING M1 OLR ACTED	RESET	17:45:00	18:00:00	
7	OHP	CO76R	ZS PROBE CHANGED	KEPT IN CIRCUIT	20:00:00	20:30:00	
8	OHP	WOBR ON CO26	PCRD O/T ACTED 3LAYERS CABLE ON THE GROUND	O/T RELEASED AND CABLE LAYING WAS DONE	21:25:00	22:00:00	PCRD CIRCUIT TO BE CHKED
9	CHP	CC 17	ZS CAGE BOLTS AMD PROBE LOOSE	ZS CAGE BOLTS TIGHT AND PROBE FIXING PROPERLY THAN OK	14:10:00	14:20:00	
10	CHP	CC32 SCR 5	LT NOT TAKING PLACE M4 TRIP FREQUENTLY	M4 OUT GOING CABLE REMOVED AT MPCB THAN OK	15:00:00	15:30:00	
11	CHP	sc7 cc 39	slew not working,oil level low,hose pipe damaged	mechanical problem	20:30:00	20:40:00	
12	CHP	CC 105 SCR 10	LUFFING NOT WORKING	OUT PUT RELAYS TIGHT IT THAN OK	16:00:00	16:30:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/06/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	scr 9 cc 104	signal missing, modem not pinging,	bypass in cm 18 i/o rack yard interlock zss cage	21:00:00	21:20:00	
14	CHP	CC 125	OLR ACTED	RESET	17:05:00	17:10:00	DUE TO OVER LOAD
15	CHP	CC 32 SCr5	LT problem mpcb 4 trip, wheel stuck mech problem	m4 removed	15:00:00	15:30:00	
16	CHP	CC 34 scr2	pcrd chain damaged	,loop provided drum arrested	20:30:00	20:45:00	informed operation
17	CHP	CC 33 scr 4	pcrd problem,cable zigzag	cble unwinding and winding done	16:10:00	16:30:00	
18	CHP	CC 125	olr acted	reset it done	20:25:00	20:35:00	
19	IOSA	TBS ON OC 13 A	LT END LIMIT ACTED DUE TO GRASS	LIMIT RELEASED	15:45:00	16:00:00	