



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	10:50:00	11:00:00	
2	OHP	BRC on CO 31	bc not running,zss acted,zss cable got cut	cable jointed	11:30:00	11:45:00	
3	CHP	CC 112 SCR8	b/w not running,power cable got cut near slew chamber	cable jointed	07:45:00	09:00:00	
4	CHP	CC 35 SCR3	b/c not running,olr acted ,mpr acted	reset	07:45:00	07:55:00	
5	CHP	CC 38 SCR6	B/W not running,b/w stucked in coal	informed operation	10:25:00	10:40:00	
6	CHP	CC 35 SCR3	slew and Lt not working	wrong complaint	10:50:00	11:10:00	
7	CHP	CC 201	motor tripped in olr	reset	10:00:00	10:10:00	
8	CHP	CC 203	olr acted	reset	12:30:00	12:35:00	
9	WT	OC 1A(b)	olr acted	reset	08:30:00	08:35:00	
10	WT	OT 1	D1 tripped in pgf1 fault	reset	08:55:00	09:00:00	
11	WT	CO 3(B)	olr acted	reset	11:05:00	11:10:00	