



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RECLAMIN G STREEM	ALL RED NEW LC-3 IC-2 TRIPPED	BC MADE ON	16:40:00	16:55:00	
2	OHP	CO-31 BRC	LT NOT WORKING	REMOTE SELECTION NOT THERE ... KEPT IN REMOTE AND TESTED	19:00:00	19:25:00	
3	OHP	CO-15	TRIPPED ON OLR	RESET DONE	17:00:00 21:10:00	17:15:00 21:20:00	
4	CHP	cc-102	BRS BYPASS REQ	BYPASSED	14:30:00	14:40:00	
5	CHP	CC-29	TT CHUT SENSOR NOT HEALTHY	NO POWER IN TT ... POWER RESTORED THEN OK	16:20:00	16:50:00	
6	CHP	CC-20	CHUT SENSOR NOT HEALTHY	CONTROL LOOSED IN PANEL ... FIXED PROPERLY	17:10:00	17:20:00	
7	CHP	CC-201 AND CC-203	TRIPPED ON OLR	RESET DONE	15:20:00	15:30:00	
8	CHP	CC-125	TRIPPED ON OLR	RESET DONE	16:30:00	16:45:00	
9	CHP	CC-32 SCR-5	SLEW NOT WORKING	OIL LEVEL LOW ... ALARM RESET DONE	17:20:00	18:00:00	
10	CHP	CC-32 SCR-5	BC NOT RUNNING	TRIPPED ON OLR ... RESET DONE	18:15:00	18:30:00	
11	CHP	CC-39	YARD EMERGENCY PB DAMAGED	REPLACED	17:20:00	17:35:00	
12	CHP	CC-39 SCR-6	BC NOT RUNNING	OLR ACTED ... RESET DONE	20:10:00	20:20:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/07/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-40 SCR-3	BC AND BW STOPPING ... BECAUSE OF SIGNAL MISSING	MACHINE LT DONE ... THEN OK	19:45:00	20:00:00	
14	CHP	CC-201	TRIPPED ON OLR	RESET DONE	20:45:00	21:00:00	
15	WT	OT-4	DRIVE TRIPPED IN PGF -4 FAULT	RESET DONE	16:20:00	16:30:00	
16	WT	CC-2 CD	TRIPPED ON OLR	RESET AFTER CLEANING	16:15:00	16:50:00	
17	IOSA	OC-13A	STOPPED ON ZSS	STONE STUCK IN CAGE ... MADE FREE	20:50:00	21:05:00	
18	IOSA	HVMCC-6	IC-1 TRIPPED	CHECKED AND MADE ON	21:10:00	21:20:00	