



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/01/2026

Area: WT

Equipment	Job
EOT Crane(C)	Main Isolator/MCCB replaced @ cabin and tested
LC 9	All drive panels blowing done
OP 6 and 8	After rake maintenance done