



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 25	SLEW NOT TAKING PLACE DRIVE TRIP	RESET THAN OK	18:45:00	19:00:00	
2	OHP	CO-43A	ZS NOT WORKING CHECKED GLASS FUSE BLOWN IN CJB	GLASS FUSE REPLACED THAN OK	17:45:00	18:00:00	
3	OHP	CO 48	OLR ACTED	RESET	16:45:00	16:55:00	
4	OHP	WOBR- ON CO 6A	LT NOT TAKING PLACE DRIVE HEALTHY NC CONTACT PROBLEM	DRIVE HEALTHY CONTACT BYPASS	21:00:00	21:15:00	
5	OHP	WOBR ON CO 29	LT M4 OLR ACTED	OLR RESET	20:45:00	21:00:00	
6	OHP	BRC ON CO 33M	YARD INTERLOCK SPURIOUSLY ACTING	ZS SPEED SETTING CHANGE FROM 7 TO 3	18:00:00	18:15:00	
7	CHP	CC-40 S-1	Reported Stacking and LT not taking place	TUL CS malfunctioning.Bypassed and LT drive reset done	14:30:00	14:50:00	TUL CS to be checked and to be kept in line
8	CHP	CC-32 SCR-5	LT not taking place	Checked and found M-3 power cable R-ph damaged. cable tapped and tested okay	15:25:00	17:30:00	
9	CHP	CC-105 SCR-7	LT not taking place	OT limit acted	17:15:00	17:30:00	
10	CHP	CC-44,107	Reported not healthy	OLR acted.Reset done	17:30:00	17:45:00	
11	CHP	CC-33 SCR-4	LT not taking place	OT acted.released and tested okay	16:00:00	16:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-104 SCR 9	Reported signal missing	LT done and checked and found okay	17:40:00	18:09:00	
13	CHP	CC-40 S-1	LT not working	PCRD cable stuck in guide. released and tested okay	16:30:00	16:45:00	
14	CHP	CC-105 SCR-7	LT not working	PCRD chain damaged	20:45:00	20:55:00	informed to mechanical
15	CHP	CC_44	Reported not healthy	OLR acted.reset done	20:40:00	20:45:00	
16	CHP	CC_54	Reported not healthy	OLR acted.reset done(2times)	17:50:00	18:05:00	
17	WT	CC-2(C)	Reported not healthy	OLR acted.reset done	16:00:00	16:15:00	
18	WT	SCO-1A(C)	Reported not healthy	OLR acted.reset done	18:50:00	19:00:00	Track jamming
19	WT	CO-3	Reported not healthy	OLR acted.reset done	16:15:00	16:20:00	
20	WT	OT-3	Overpushing	Sensor temporary bypassed and after tripping kept back in line	20:20:00	20:40:00	
21	WT	OP-6	Crossed cut off section	Busbar shorted by jumpers.After pusher movement jumpers removed	20:40:00	21:10:00	