



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-20	NO DRIVES WORKING ... MAIN CONTROL TRIPPED	MADE ON	22:25:00	22:40:00	
2	OHP	BRC ON CO-32	BC NOT STARTING ...CHUT SENSOR NOT WORKING	BYPASSED AND INFORMED OPERATION	23:45:00	00:15:00	
3	OHP	RBF-3A	TRIPPED .. DUE TO MATERIAL FALLEN ON POWER JB .. ONE PHASE EARTH FAULT	MATERIAL REMOVED .. AND TESTED	23:55:00	00:20:00	
4	OHP	CO-77	TRIPPED ON OLR	RESET DONE	02:58:00	03:03:00	
5	OHP	CO-33M	TRIPPED ON OLR	RESET DONE	02:50:00 03:30:00	03:00:00 03:40:00	
6	OHP	BRC ON CO-8A	CT STOPPING SOMETIMES	CHECKED ... NO ELECTRICAL PROBLEM	03:45:00	04:00:00	
7	OHP	CR-1	FAIL TO START	CONTROL RECYCLED AND TESTED	04:10:00	04:20:00	
8	OHP	BRC ON CO-32	LT NOT WORKING SKEW ACTED	RESET DONE	05:10:00	05:20:00	
9	OHP	BRC ON CO-32	BC MCCB TRIPPED	STONE STUCK IN BELT ... DIRECTION REV THEN NORMALIZED AFTER STONE REMOVAL	05:00:00	05:45:00	
10	OHP	OP-4	PAD FALLEN AT COL. NO 44 ACB TRIPPING	POWER BLOCK GOT AT 5:30 PAD CHANGING GOING ON	04:15:00	06:00:00	
11	CHP	CC-34 SCR-2	BC STOPPING DUE TO SIGNAL MISSING	LT DONE THEN OK	03:30:00	03:50:00	
12	CHP	CC-33 SCR-5	LT NOT WORKING ... DRIVE TRIPPED AND PCRD OT ACTED	RESET AND OT RELEASED	05:15:00	05:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 103	CHUT SENSOR ACTED	CLEANED THEN OK	05:00:00	05:10:00	