



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR (2TIMES)	RESET DONE	06:30:00 07:30:00	06:40:00 07:40:00	
2	OHP	CO-25	TRIPPED ON OLR (2TIMES)	RESET DONE	07:00:00 09:00:00	07:10:00 09:10:00	
3	OHP	BRC ON CO-32	REPORTED HYDRAULIC PUMP NOT RUNNING FOUND COOLING FAN MPCB TRIP	MADE ON THAN OK	06:30:00	06:45:00	
4	OHP	CO-85	TRIPPED ON OLR (3TIMES)	RESET DONE	10:40:00 10:50:00 11:00:00	10:45:00 10:55:00 11:10:00	
5	OHP	BRC ON CO-8A	REPORTED ALL DRIVES ARE NOT RUNNING ACB TRIP	ACB MADE ON THAN OK	11:10:00	11:25:00	
6	OHP	VF-16A	NOT RUNNING M-1 OLR ACTED DUE TO MOTOR CABLE INSULATION DAMAGED	CABLE TAPPING WAS DONE AND M-1 RESET DONE	13:10:00	13:30:00	
7	CHP	CC-27A	REPORTED STOPPING ON ZSS FOUND ZSS CAGE STUCK UP WITH COAL PIC	REMOVED THAN OK	09:50:00	10:00:00	
8	CHP	CC-53	MPCB TRIPPED (3TIMES) DUE TO MATERIAL JAMMING	RESET DONE	08:20:00 10:20:00 10:45:00	08:25:00 10:25:00 10:50:00	
9	CHP	CC-125	TRIPPED ON OLR	RESET DONE	09:55:00	10:00:00	
10	CHP	CC-31 SCR-4	REPORTED B/C NOT RUNNING FOUND DISCHARGE CHUTE JAMMING	INFORMED TO OPERATION	10:30:00	10:40:00	
11	CHP	CC-104 SCR-9	REPORTED SLEW NOT WORKING MPD TRIP	RESET DONE	10:30:00	10:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-203	TRIPPED ON OLR	RESET DONE	11:10:00	11:15:00	
13	CHP	CC-104 SCR-9	REPORTED B/C NOT RUNNING FOUND MULTI DISK DAMAGED	INFORMED TO MECHANICAL	13:10:00	13:25:00	