



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF-19	Reported tripped	M-1 OLR acted.Reset done	03:00:00	03:10:00	Due to material jamming
2	CHP	Cc-32 S-3	B/C not running	OLR acted.Reset done	00:55:00	01:05:00	
3	CHP	Cc-201	Reported tripped	OLR acted.Reset done	01:30:00	01:45:00	
4	CHP	Cc-25	ZSS acted	Cage stuck with material.Made free and tested okay	00:00:00	00:10:00	
5	CHP	Cc-58	Reported tripped	D-2 motor OLR acted.Reset done	23:30:00	23:45:00	
6	CHP	Cc-51	MPD tripped	Reset done(7 times)	03:00:00	05:00:00	