



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/07/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 20	LT not taking place,drive trips in ol	reset	14:50:00	15:00:00	
2	OHP	RSCO 10 A (c)	mpcb trips due to jamming	made it on	15:00:00 16:00:00	15:10:00 16:10:00	
3	OHP	TBS on CO 22	L b/c not running,olr acted	reset	17:00:00	17:10:00	
4	OHP	BRC on CO 31	b/c not stopping after yard conveyor stops,B/C contactor got welded	contactor replaced with spare feeder	20:40:00	21:30:00	
5	OHP	WOBR on CO 6A	LT not taking place,drive trips in overload	reset	21:30:00	21:45:00	
6	CHP	CC 131	tripped due to olr	reset	19:09:00	19:12:00	4 times
7	CHP	RG3	failed to start,incomer 1 tripped in 1-2 LBDS 8	made it on	16:05:00	16:30:00	
8	CHP	CC 34	not healthy,D/E cjs acted,jamming	informed operation	15:00:00	15:15:00	
9	CHP	CC 32	B/C not running,decksheet jamming,olr acted	informed operation, olr reset	15:39:00	15:50:00	
10	CHP	CC 104 SCR 9	no power,incomer 1 tripped in 1-2 LBDS 8	made on	16:00:00	16:30:00	
11	CHP	CC 32 scr 5	LT not taking place,M2 mpcb trips	made it on	17:26:00	17:36:00	
12	CHP	CC 33 SCR4	LT reverse not working end limit switch cable loose connection@ old joint	old joint properly connected	17:45:00	18:00:00	
13	CHP	CC 112 scr 8	no power, acb tripped	made it on	19:07:00	19:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/07/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 19	OLR acted	reset	16:15:00 21:40:00	16:20:00 21:44:00	
15	WT	OT 1	D1 trips in pgf1 fault	reset	17:55:00	18:00:00	
16	IOSA	TBS	LT not working,end limit acted due to bushes	end limit released	18:30:00	18:45:00	