



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/02/2026

Area: WT

Equipment	Job
OP 10 jobs	Mast placed and alignment done ( welding work is going on)
OP 10 jobs	Old panel stools removed and made new stool and placed D B Rs
OP 10 jobs	D1 Motor cable jointing done and 1 no D B R shifted from new building
EOT Crane(O)	Main Hoist ,brake rectifier replaced
OP 2 , 3 and 6	After rake maintenance done