



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 21	stop in ZSS fault,zss cage module ok,belt slipping	informed operation and mech	08:45:00	08:55:00	
2	OHP	BRC on 34	LT not working,wrong complaint	checked LT working ok	07:45:00	08:00:00	
3	OHP	RSCO 9A	olr acted	reset	10:30:00	10:40:00	
4	CHP	CC 47	motor fail to start	power and control made off and on	07:05:00	07:10:00	
5	CHP	CC 45	motor stop due to BS	mechanical adjusted belt	07:25:00	07:35:00	
6	CHP	CC 34 scr2	LT not working,CAM switch common control supply missing , cable got cut	cable rejoined	08:30:00	08:45:00	
7	CHP	CC 104 SCR 9	B/c not running,CJS acted,jamimng	informed operation	09:30:00	09:40:00	
8	CHP	CC 104 SCR 9	B/C not running,	fault reset done than ok	12:20:00	12:30:00	
9	CHP	CC 34 SCR 2	LT not taking place,OT acted	OT released	11:40:00	11:50:00	
10	WT	CC 3(c)	olr acted,mpcb tripped	mpcb made on	11:45:00	11:50:00	
11	IOSA	OLD WOBR	LT not taking place,end limit acted due to bushes	released	08:15:00	08:30:00	