



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/06/2025

Incharge(s): V Balaji Naik

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO29	Over load acted 3 times	Reset done	17:00:00 20:30:00 21:10:00 21:35:00	17:15:00 20:45:00 21:20:00 21:40:00	
2	OHP	CO35	Over load acted	Reset done	19:40:00	19:50:00	
3	OHP	TBS on CO20	Left boom not working found MPCB trip	Reset and made on	17:20:00	17:40:00	
4	OHP	CO42a	BRS bypassed as per operational request	Entered in log book	20:45:00	21:00:00	
5	CHP	SCR2 on CC35	Signal problem from CCR to SCR2	Antena and pick tail cable changed then ok	15:10:00	18:00:00	
6	CHP	CC33	Due to over load on CC51	Reset done	18:50:00	19:00:00	
7	CHP	CC112	Stpped due to over load on C51	Reset done	20:55:00	21:00:00	
8	WT	OP3	Not working found middle pad fallen down near cabin area	With c clamp adjustment middle pad adjusted to normal position then ok	14:45:00	15:00:00	