



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	ZSS ACTING DUE TO BELT SLIPPING	INFORMED TO OPRN	15:45:00	16:00:00	
2	OHP	WBR ON CO 29	LT M4 TRIPPED	MADE IT ON	20:25:00	20:40:00	
3	OHP	CO 67	OLR ACTED	RESET	18:00:00	18:15:00	
4	CHP	CC 28	OLR ACTED	RESET	20:00:00 20:25:00	20:05:00 20:30:00	
5	CHP	SCR2 ON CC 34	ZSS PROBE REPLACED	KEPT IN CIRCUIT	14:30:00	14:45:00	
6	CHP	SCR 6 ON CC 38	LT M1 TRIPPED	MADE IT ON	15:30:00	15:45:00	
7	CHP	SCR2 ON CC 34	O/T ACTED	RELEASED	16:00:00	16:15:00	
8	CHP	SCR 6 ON CC 38	LT DRIVE TRIPPED	RESET	20:10:00	20:20:00	
9	CHP	R1	LUFF DOWN LIMIT GOT STUCK	MADE IT FREE	20:00:00	20:15:00	
10	CHP	CC 51	OLR ACTED	RESET	20:40:00	20:45:00	
11	WT	OC 2A	LOOSE CONNECTION IN ZSS MODULE	TIGHTENED	16:00:00	16:20:00	