



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/02/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-6	ZSS acting	Probe damaged and cage fixing bolt missing.Probe replaced and cage bolts replaced and tested okay	06:50:00	07:20:00	
2	OHP	CR-2A	ZSS acting	Probe gap adjusted and tested okay	13:25:00	13:35:00	
3	OHP	RBF-3A(C/D)	LT not moving	Tripped due to material jamming.Reset done	10:00:00	10:15:00	
4	OHP	CO-6	ZSS acting	Module problem.Module replaced and tested okay	13:30:00	14:05:00	
5	CHP	CC-27	Reported CJD not acting	Probe wire got cut. Rejointed and tested okay	12:00:00	12:15:00	
6	CHP	CC-51	MPD tripped	Reset done(4 times)	07:40:00	10:55:00	
7	CHP	CC-58	Reported tripped	OLR acted.Reset done	06:50:00	07:05:00	
8	CHP	CC-39 SCR-6	B/C not running	Chute sensor acted.Sensor cleaned and tested okay	08:10:00	08:25:00	
9	CHP	Cc-108	Reported tripped	OLR acted.Reset done(2 times)	10:05:00	12:05:00	
10	WT	EOT in ore tippler	Reported Hoist not taking place	Brake rectifier failed.Replaced and tested okay	11:00:00	12:00:00	