



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/06/2025

Shift: A

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 20	BRS to be bypassed as per operation request due to belt pieces	BRS bypassed	07:45:00	07:50:00	again kept in circuit as per operation request
2	OHP	CO 19	BRS to be bypassed as per operation request due to belt hole	BRS bypassed	08:45:00	08:55:00	again kept in circuit as per operation request
3	OHP	CO 29	OLR acted	reset done	09:15:00	09:20:00	
4	OHP	BRC on CO 8A	BC direction to be changed as per operation request due to material overload on belt bcz of belt loose and pully touching chute hood	BC direction changed	07:45:00	08:00:00	again direction changed to original
5	OHP	BRC on CO 31	CT not taking place	operator cabin side limit stucked, made free	10:45:00	11:05:00	
6	CHP	CC 33	Not healthy , MPR tripped (2 times)	reset done	09:30:00	09:50:00	
7	CHP	CC 35 , SCR 1	BW not running	OLR acted , reset done	10:45:00	10:55:00	
8	CHP	CC 35 , SCR 1	LT not working	Drive tripped , reset done. Also track jamming , informed to operation	11:00:00	11:10:00	
9	CHP	CC 32 , SCR 5	BC not running	Stopped in zero speed. Found that material stucked in zss cage, also hole in belt . Informed to operation and mechanical	12:00:00	12:10:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/06/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC 105, SCR 10	No drives running	Main breaker tripped, made on	12:55:00	13:05:00	
11	CHP	CC 44	OLR acted	reset done	12:35:00	12:40:00	
12	CHP	CC 35 , SCR 1	Slew not working	OLR acted , reset done	13:00:00	13:10:00	
13	CHP	cc-114	tripped on olr	reset done	13:55:00	14:00:00	