



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/12/2025

Area: OHP

Equipment	Job
wbr-1,2,3	bucket wheel motor inspection is done.
co-29 ; wbr on co-29	ppm is done
brc-3 on co-34 ; co-19	ppm is done. co-19 motor ppm is done
rco-1a h/e ; 36b gallery ; 35a gallery areas	lighting is improved
ground hopper	hoist ppm is done, lighting timer is replaced and restored lighting circuit.
1-141lc4 to 1-14lc6	profibus cable laid between vf-22 level to lc6 and restored redundant plc communication.
co-13 belt and carriage ; co-15 ,tt-2; co-8a ; db-1	motor and feeder side ppm is done.