



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/06/2025

Area: CHP

| Equipment | Job |
|------------------------|---|
| CC 222/223 gallery | Lighting ckt problems rectified and improved lighting |
| CC 27 ZSS | Module shifted to near zss cage and tested |
| CC 28,109,110,33,SCR 4 | PPM was done |
| SCR 6 | Cable chamber material cleaning done |
| R 1 | PCRD OT limit adjusted and kept in ckt |
| SCR 2 | Reclaiming mode cage interlock provided |