



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/09/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 85	OLR acted	reset	10:25:00	10:30:00	
2	OHP	CC 37 SCR7	LT not working,PCRD OT acted	OT released	11:10:00	11:25:00	
3	CHP	VF 103	OLR acted due to jamming	informed operation and feeding reduce to 500 rpm	10:19:00	10:29:00	
4	CHP	CC 130 TIS	running fbk not showing in CCR ,Emergency PB acted	Emergency PB released	10:15:00	10:30:00	
5	CHP	CC 51	MPD trips due to feeding conveyor overload	reset	06:50:00	06:55:00	13 times
6	CHP	CC 54	MPD trips	reset	07:30:00	07:35:00	
7	CHP	CC 33 R1	brs acted,	sensor cleaned	09:36:00	09:45:00	
8	CHP	CC 108	OLr acted	reset	13:05:00	13:10:00	
9	CHP	CC 31 SCR4	slew not working,slew limit acted	limit released	12:48:00	12:55:00	
10	WT	OT 1	not moving,D1 tripped in pgf1 fault	reset	07:00:00	07:05:00	