



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/09/2025

Area: WT

Equipment	Job
OP 5	All 3nos power collector pads , top C-Clamp and jumper replaced
CT 1	hopper area near M1 ,200 w LED replaced and grill area 2 nos tubes installed