



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/10/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	TRIPPED ON OLR	RESET DONE	14:05:00	14:10:00	
2	OHP	CO-3A	STOPPING ON ZSS ... CAGE PROBLEM	FIXED PROPERLY	14:30:00 20:20:00	15:00:00 20:30:00	
3	OHP	CO-58 BD	TRIPPED OBN OLR	RESET DONE	20:35:00	20:40:00	
4	OHP	CO-111	TRIPPED ON OLR	RESET DONE	15:30:00	15:40:00	
5	OHP	BRC ON CO-32	YARD INTERLOCK ZSS CAGE STUCK	MADE FREE	16:20:00	16:45:00	
6	OHP	TBS ON CO-20	R -LUFF OLR ACTED	RESET DONE	19:45:00	19:55:00	
7	OHP	BRC ON -8A	PCRD UP NOT WORKING	LOOSE CONNECTION ... FIXED PROPERLY	18:30:00	18:45:00	
8	CHP	CC-52	MPD TRIPPED	RESET DONE	19:35:00	19:45:00	
9	CHP	CC-113A	TRIPPED ON OLR	RESET DONE	19:15:00	19:25:00	
10	CHP	CC-116	OLR ACTED	RESET DONE	16:05:00	16:15:00	
11	CHP	CC-104 SCR-9	SLEW AND BW NOT WORKING	PUMP MPD TRIPPED ... RESET DONE	15:50:00	16:10:00	
12	CHP	CC-35 SCR-3	BW NOT RUNNING ... CP-1 ACTED	RESET DONE	18:40:00	18:50:00	
13	CHP	CC-112 SCR-8	SLEW NOT WORKING 30 DEGREE ACTED	RELEASED	19:45:00	20:00:00	
14	CHP	CC-203	OLR ACTED	RESET DONE	19:50:00	20:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/10/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	SCR-10 CC-105	LUFF NOT WORKING	UP LIMIT ACTED ... RELEASED	19:18:00	19:30:00	
16	IOSA	FLS WBR	YARD TO BOOM ZSS PROB PROBLEM	REPLACED	18:00:00	18:30:00	
17	IOSA	SCO-1A CD	TRIPPED ON OLR	RESET DONE	21:00:00	21:30:00	