



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	B/W-2 OLR ACTED	RESET DONE	16:00:00	16:20:00	
2	OHP	CO-35	OLR ACTED	RESET DONE	17:20:00	17:30:00	
3	OHP	BRC ON CO-34	LT NOT TAKING PLACE CHECKED AND FOUND PCRD O/T AND GUIDE PROBLEM	O/T RELEASED AND MECHANICAL GUIDE ADJUSTED THAN OK	18:25:00	18:40:00	
4	OHP	CO-26	OLR ACTED	RESET DONE	19:40:00 21:10:00	19:55:00 21:20:00	
5	OHP	RSCO-10A (C/D)	OLR ACTED	RESET DONE	15:50:00	16:00:00	
6	OHP	CO-14	MPD-OLR ACTED	RESET DONE	20:10:00	20:20:00	DUE TO MATERIAL JAMMING
7	OHP	TT-2 ON CO-15	TT-2 NOT MOVE CHECKED AND FOUND PCRD CABLE OLD JOINT OPENED	C/S BYPASSED AFTER CABLE JOINT COMPLETED C/S KEPT IN CIRCUIT	16:00:00	17:30:00	
8	OHP	CC-40 SCR-3	B/C OLR ACTED	RESET DONE	17:40:00	17:50:00	
9	OHP	CO-29	OLR ACTED	RESET DONE	21:40:00	21:50:00	
10	CHP	CC-33 R-1	B/C NOT RUNNING CHECKED AND FOUND DUE TO WET COAL JAMMING	INFORMED TO OPERATION	15:20:00	15:35:00	
11	CHP	CC-40 SCR-3	LT DRIVE TRIP	RESET DONE THAN OK	16:00:00	16:20:00	
12	CHP	CC-112 SCR-8	B/C OLR ACTED	RESET DONE	17:15:00	17:30:00	



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 28/09/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-36 SCR-1	LUFF DOWN NOT WORKING CHECKED AND FOUND DOWN LIMIT ACTED	OPERATION REQUIREMENT DOWN LIMIT BYPASSED	17:25:00	17:45:00	KEPT IN CIRCUIT SHIFT ENDING
14	CHP	CC-37 SCR-7	LT NOT TAKING PLACE PCRD O/T ACTED (2TIMES)	RELEASED	20:10:00 20:40:00	20:25:00 20:55:00	
15	CHP	CC-105 SCR-10	B/C OLR ACTED	RESET DONE	21:20:00	21:40:00	
16	CHP	CC-51	MPD TRIP (5TIMES) FEEDING CONVEYOR STOP	RESET DONE	15:00:00	17:50:00	
17	CHP	CC-54	OLR ACTED (6TIMES)	RESET DONE	16:50:00	19:45:00	
18	CHP	CC-117	OLR ACTED	RESET DONE	18:45:00 19:35:00	18:55:00 19:50:00	
19	CHP	CC-131	OLR ACTED (2TIMES)	RE4SET DONE	18:25:00 21:05:00	18:30:00 21:10:00	
20	WT	OT-2	DRIVE -2 (PGF-2) TRIP (2TIMES)	RESET DONE	16:30:00	17:00:00	
21	WT	OT-4	DRIVE-2 (PGF) TRIP (2TIMES) DUE TO MECHANICAL PROBLEM	DRIVE FAULT RESET DONE THAN INFORMED TO MECHANICAL	16:45:00 18:10:00	17:00:00 18:20:00	
22	WT	SCO-1A	CONTROL TRIPPING	CHECKED AND FOUND P/C CABLE GOT CUT AND GETTING EARTHED.P/C CABLE ISOLATED FROM JB AND TESTED OKAY	17:50:00	18:45:00	
23	WT	OT-2	DRIVE TRIPPING ON PGEF FAULT	CHECKED AND FOUND MIDDLE ROLLERS JAMMED AND NOT ROTATING.INFORMED TO OPERATION INCHARGE	21:00:00	22:00:00	