



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-8	Reported tripped	OLR acted.Reset done(3 times)	22:20:00	03:40:00	
2	OHP	TBS on CO-22	Reported operations not taking place	Control off.made on and tested okay	02:45:00	03:00:00	
3	OHP	CO-26	Reported tripped	OLR acted.Reset done	05:55:00	06:00:00	
4	CHP	CC-54	Reported tripped	OLR acted.Reset done(7 times)	23:30:00	03:00:00	
5	CHP	Cc-51	Reported tripped	MPD acted.Reset done(5times)	00:00:00	02:20:00	
6	CHP	CC-131	Reported tripped	OLR acted.Reset done(2 times)	23:30:00	03:25:00	
7	CHP	CC-33 SCR-5	HT cable flashover at joint pending from B shift	Cable meggered, joint made by dnw,2 HT fuses replaced at I/O and operations tested okay	22:00:00	02:00:00	
8	CHP	Cc-38 SCR-6	Reported LT not taking place	M-2 tripped.Reset done and tested okay	01:18:00	01:29:00	
9	CHP	CC 105 SCR-10	B/C not running	Fluid oil leakage.	01:15:00	01:30:00	Informed to mechanical
10	CHP	CC 34 SCR-1	Luffing not taking place	wrong complaint	02:51:00	03:02:00	
11	CHP	Cc-32 R-1	Luffing not working	mechanical problem	04:20:00	04:32:00	Informed to mechanical
12	WT	OP-3	Reported no movement	Pads fallen at column 31-32.Pad,jumper,c and u clamps replaced	01:30:00	02:30:00	Not a running complaint
13	WT	OC-1A	Reported tripped	OLR acted.Reset done(3 times).	04:50:00	05:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/11/2025

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	IOSA	BRC	Reported not starting	Checked and yard ZSS cage stuck up with stone. Removed and tested okay	01:40:00	01:50:00	