



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/12/2025

Area: OHP

Equipment	Job
1-141lc4 to lc6	profibus cable laid between vf-22 level to lc6 and restored redundant plc communication.
co-13 belt and carriage ; co-15 ,tt-2; co-8a ; db-1	motor and feeder side ppm is done.