



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 03/02/2026

Area: IOSA

Equipment	Job
LBDS-2	6.6KV BUS COUPLER DEFECT RECTIFICATION IN PROGRESS. BREAKER SPRING CHARGING MOTOR FAILED.
OC-17A	PPM DONE ON MOTOR SIDE
PLC COMMUNICATION	COMMUNICATION FAILED IN LC-1 AND OM-1 4 TIMES. POWER TO RACK RECYCLED AND GIVEN CLEARANCE AFTER COMMUNICATION ESTABLISHED