



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 19/11/2025

Area: OHP

| Equipment | Job |
|--|--|
| wbr-2 on co-25 | It m2 motor is checked and restored in circuit. |
| brc-5 on co-32 | estop near operator cabin guardis provided and cjb's tightness is ensured. |
| co-32 h/e hoist | ppm is done |
| tbs- on co-22 ; co-22,32 | motor and panels ppm is done |
| brc-3 shifting | shifted from co-34 to 33m |
| tt-4 | zss module, probe old ones recovered. |
| co-18,76r,3b | motor and panel ppm is done |
| co-69,70,37a,36a,33a,31a,32a | chute vibrators inspection is done |
| co-8a,38a | safety devices ppm is done; co-8a pull chord reset done and restored in circuit. |
| co-68 | motor and panel side ppm is done |
| locp-2 rsco-2a level and stair case, crusher areas | illumination is improved. |
| cr-1a,2a,3a | hydraulic and lubrication power packs maintenance is done. |
| co-16a,16b | field devices ppm is done ; 16a h/e and 16b h/e illumination is improved |
| co-26 | motor winding side lug damaged, replaced and observed currents. |