



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/05/2025

Area: WT

Equipment	Job
OP 9	
	lighting circuit problem,rectified
OP 5	motors checked found D4 slipring problem,unit removed and rotor cable shorted and drive bypassed
	after rake maintenance done

CO3 &4 stair case

OP 1,2,3,4,6,CP1 &3