



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co25	slew not working,olr acted	reset	05:12:00	05:24:00	
2	OHP	TBS on co 24	Lt not working,control is in off,M4 OLR acted	control on,olr reset	05:28:00	05:43:00	
3	CHP	CC 32 SCR 5	LT not working,drive tripped	reset done	22:25:00	22:35:00	
4	CHP	CC 32 SCR5	b/c not running,mpd tripped,jamming	reset,informed operator	22:40:00	22:50:00	
5	CHP	CC 37 SCR7	signal missing,	Lt done than ok	04:15:00	04:25:00	
6	CHP	CC 223	drive tripped	reset	04:15:00	04:30:00	
7	CHP	CC 31 SCR4	b/w not running,olr	reset	05:40:00	05:50:00	
8	WT	OP 6	not moving@coupling time,d5 olr acted	reset	23:25:00	23:40:00	
9	WT	OT 3	d2 tripped in encoder fault	checked encoder note move smoothly,encoder replaced,	04:35:00	05:55:00	pinion problem mechanical