



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	R1 ON CC31	bc not running/olr acted due to jamming	reset done	07:00:00	07:15:00	
2	CHP	R1 ON CC 31	LUFFING NOT TAKING PLACE/JAMMING AT BW AREA	RASET DONE	08:40:00	09:20:00	
3	CHP	SCR 2 ON CC35	It not taking place/pcrd tension acted	tension released	08:10:00	08:25:00	
4	CHP	scr 7on cc39	It not taking place/pcrd tension acting frequently	control ckt adjusted for R1	10:45:00	11:20:00	PCRD GUIDE ADJ.by mech.
5	CHP	cc 219	d/end c/s acted	reset done	10:15:00	10:30:00	
6	CHP	cc 108	zss acted/didnt found any problem	all terminals tightend atcjb and module	09:45:00	10:05:00	
7	CHP	cc132	brs acting due to offcentreing	inform to operation	12:10:00	12:20:00	
8	WT	ot 4	d2 drive fault(pgf)	reset done	08:30:00	08:40:00	
9	IOSA	tbs on oc 13a	c/s acted /rbc	reset done	11:35:00	11:50:00	