



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/01/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	OLR acted	reset	02:15:00	02:20:00	
2	OHP	TBS on CO 21	all drive not working,ACB is in off,not getting on	ACB top cover opened and made it on	00:15:00	00:40:00	
3	OHP	VS 3A	OLr acted 2 times	reset	02:35:00	02:45:00	
4	OHP	TBS on CO22	cjs not healthy, signal missing	modem power recycle than ok	04:05:00	04:25:00	
5	CHP	CP 1	no power @col no 20	power made on,B type isolator,CU bar in Y phase ,remove and inserted and pusher send to parking zone	22:00:00	23:30:00	
6	CHP	CC 54	motor tripped	reset	23:45:00	23:50:00	
7	CHP	CC 107	bRS acting without problem	check and found belt overload and spillage	00:10:00	00:20:00	
8	CHP	CC 213 and 216	CJS acted	cleaning done,than ok	00:30:00	00:40:00	
9	CHP	CC 108	motor olr acted	reset	00:50:00	01:00:00	
10	CHP	CC 18	ZSS acted,belt offcentering	informed operation and mechanical	23:45:00	23:50:00	