



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/01/2026

Area: WT

Equipment	Job
OP 2	All Motors megaring and control checking done 1AT,2AT,3AT timers time adjusted (12,7,6 sec)
CP 4	Top power collector set replaced and Trolley Line inspection and top bus bar alignment done @73 and 33
OP 6	Section isolaters maintenance done 3 nos (Line completed)
OP 1,5,6 and 8	After rake maintenance done
CP 1 and 4	After rake maintenance done
MIS	LC 10B room cleaning done