



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|---|----------|----------|--|
| 1 | OHP | cO 29 | olr acted | reset | 22:50:00 | 22:55:00 | 3 times |
| 2 | OHP | CO 26 | olr acted | reset | 03:30:00 | 03:40:00 | |
| 3 | OHP | TBS on CO 19 | LT not working,M3 motor tripped | reset | 00:40:00 | 00:55:00 | |
| 4 | OHP | CO 6A | EMERGENCY Stop in panel,power mains ,MCCB magnet and conveyor is in off | power mccb ,magnet ,conveyor and mains made on | 23:30:00 | 23:45:00 | may be not normalised after PPM in general shift |
| 5 | CHP | CC 35 SCR 3 | LT not working,m4,8,9 mpcb trips track jamming | made it on,informed operation | 02:25:00 | 02:40:00 | |
| 6 | CHP | CC 45 | motor not running,olr acted | reset | 02:40:00 | 02:50:00 | |
| 7 | CHP | CC 107 | olr acted, mpd trips | reset | 04:20:00 | 04:30:00 | |
| 8 | CHP | CC 54 | olr acted | reset | 04:52:00 | 04:57:00 | |
| 9 | CHP | CC 38 SCr 6 | Lt not taking place,M1 and M2 mpcb trips | made it on | 04:10:00 | 04:20:00 | |
| 10 | WT | AF 4(O) | trips in ground fault | ground fault setting B306 set 0,after that tripped in speed deviation fault | 05:40:00 | 06:20:00 | informed operation and mechanical ,to be checked pan |