



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/09/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment       | Problem                                | Action  | From                 | To                   | Remarks |
|-------|------|-----------------|--|---|----------------------|----------------------|---------|
| 1     | OHP  | CO-63           | MPCB TRIPPED                           | RESET DONE                                      | 02:30:00<br>02:45:00 | 02:40:00<br>02:54:00 |         |
| 2     | OHP  | CO-61           | TRIPPED ON OLR                         | RESET DONE                                      | 00:20:00             | 00:35:00             |         |
| 3     | OHP  | CO-19 TBS       | LT NOT WORKING DUE TO LT IN LOCAL MODE | KEPT IN REMOTE                                  | 23:45:00             | 00:00:00             |         |
| 4     | OHP  | CO-67           | TRIPPED ON OLR                         | RESET DONE                                      | 22:55:00             | 23:05:00             |         |
| 5     | CHP  | CC-15           | TRIPPED ON OLR                         | RESET DONE                                      | 03:40:00             | 03:50:00             |         |
| 6     | CHP  | CC-37<br>SCR-7  | SIGNAL MISSING                         | LT DONE THEN OK                                 | 00:00:00<br>01:00:00 | 00:20:00<br>01:30:00 |         |
| 7     | CHP  | CC-32<br>SCR-5  | BC TRIPPED ON OLR                      | RESET DONE                                      | 00:00:00             | 00:20:00             |         |
| 8     | CHP  | CC-112<br>SCR-8 | BC NOT STARTED                         | FAULT RESET DONE                                | 00:00:00             | 00:25:00             |         |
| 9     | CHP  | CC-112<br>SCR-8 | BC TRIPPED ON OLR                      | RESET DONE                                      | 02:45:00             | 03:00:00             |         |
| 10    | CHP  | CC-42           | TRIPPED ON OLR                         | RESET DONE                                      | 03:45:00             | 03:50:00             |         |
| 11    | CHP  | CC-40<br>SCR-3  | SLEW NOT WORKING                       | LIMIT ACTED DUE TO COAL JAMMING ...<br>RELEASED | 05:15:00             | 05:30:00             |         |
| 12    | CHP  | CC-54           | TRIPPED ON OLR ( FOUR TIMES )          | RESET DONE                                      | 23:05:00             | 02:10:00             |         |
| 13    | CHP  | CC-131          | TRIPPED ON OLR                         | RESET DONE                                      | 01:50:00<br>04:50:00 | 01:55:00<br>04:55:00 |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/09/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem  | Action     | From     | To       | Remarks |
|-------|------|-----------|--|------------|----------|----------|---------|
| 14    | CHP  | CC-51     | MPD TRIPPED (9 TIMES FEEDING CONVEYOR STOPPED) | RESET DONE | 03:05:00 | 05:05:00 |         |
| 15    | WT   | OC-1A     | FAIL TO START DUE TO PULL CORD ACTED           | RELEASED   | 23:00:00 | 23:30:00 |         |