



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/05/2025

Area: CHP

Equipment	Job
CC 20	CONTACTOR INCOMING AND OUT GOING BOLTS REPLACED
CC 26A	DRIVE END AREA 400 SV LAMP REPLACED
JH 5, JH6 HOIST	MAINTENANCE DONE