



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 33m	CT not working,drive tripped	reset	16:50:00	17:00:00	
2	OHP	CO 26	cjd acted,fuse blown in TB	direct terminated	17:50:00	18:10:00	
3	CHP	CC 44	e pb contact problem	contact replaced	14:35:00	14:45:00	
4	CHP	CC 39 SCr6	LT not working,drive tripped	reset	16:05:00	16:15:00	
5	CHP	CC 105 SCR10	b/c not working,signal problem	modem power recycle done	15:50:00	16:10:00	
6	CHP	CC 213	conveyor stopped , CJS acted	reset	16:35:00	16:50:00	
7	CHP	CC 103	FLAP GATE MPCB TRIPPED	MADE IT ON	15:35:00	15:45:00	
8	CHP	CC 51	mpd acted 2 times	reset	14:50:00	14:55:00	
9	CHP	CC 54	olr acted	reset	15:10:00	15:15:00	
10	WT	OT3	encoder fault, tripped 3 times	reset	17:20:00	17:25:00	
11	WT	CO 4 (b)	mpcb tripped	made on	20:30:00	20:35:00	
12	WT	OT 2	PGF1 FAULT ACTED	RESET	21:40:00	21:45:00	
13	IOSA	TBS	communication problem,boom conveyor stopped	modem power recycled	18:20:00 20:35:00	18:35:00 20:55:00	