



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/10/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-8A	CT NOT TAKING PLACE CHECKED AND FOUND CT LIMIT ACTED	RELEASED	16:30:00	16:50:00	
2	OHP	TW-18 ON CO-33S	TRIPPED ON OLR	RESET DONE	17:30:00	17:50:00	
3	OHP	RBF-3A	OLR ACTED (2TIMES)	RESET DONE	20:25:00 20:50:00	20:30:00 21:00:00	
4	CHP	CC-51	OLR ACTED	RESET DONE	15:20:00	15:30:00	
5	CHP	cc-203	PULL CORD ACTED	RELEASED	14:20:00	14:30:00	
6	CHP	CC-36 SCR-2	PCRD GUIDE PROBLEM	DRUM ARRESTED .. CABLE UNWIND DONE ... MOTOR SUPPLY REMOVED	17:40:00	18:30:00	
7	CHP	CC-34 SCR-2	SLEW 30 DEGREE ACTED	RELEASED	17:05:00	17:25:00	
8	CHP	CC-112 SCR-8	SLEW NOT WORKING	30 DEGREE LIMIT ACTED	18:25:00	18:45:00	
9	CHP	CC-204	TRIPPED ON OLR	RESET DONE	17:35:00	17:55:00	
10	WT	OT-1	D1 TRIPPED ON PGF-1 FAULT	RESET DONE	18:30:00	18:40:00	