



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/06/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on co 20	all drive not running,acb tripped,emergency pressed in operator cabin	ACB made on	15:40:00	16:00:00	
2	OHP	CO 9A	CJD acted	released	18:20:00	18:30:00	
3	OHP	TBS on co 21	R b/c not running,olr acted due to material jamming	olr reset	18:30:00	18:45:00	
4	OHP	WOBR on co 26	B/C stopping in zss,zss cage stucked	cage cleaned	19:30:00	19:45:00	
5	OHP	CO 39	olr acted	reset	19:50:00	20:00:00	
6	OHP	TBS on co 21	r B/c not running,ZSS acted probe damaged	probe replaced	21:30:00	22:00:00	
7	CHP	CC 105 SCR 10	signal missing,b/c not running,lighting complaint mcb tripped	Plc power recycled,lighting mcb made on	19:19:00	19:35:00	
8	CHP	CC 36 SCR1	luffing not working,up limit lever stucked and OLr acted	up limit released ,Olr reset	19:15:00	19:30:00	
9	CHP	CC 36 SCR1	slew not working,drive trips in ol	reset	20:50:00	21:00:00	
10	CHP	CC 104 SCR 9	stacking mode not showing	loop removed in CM18 for stacking mode	14:18:00	14:30:00	
11	CHP	CC 132	tripped due to olr	reset	15:50:00	16:00:00	2 times
12	CHP	CC 131	olr acted	reset	21:20:00	21:25:00	2 times