



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/10/2025

Area: CHP

Equipment	Job
HT spare motors	Meggered the motors at HT motor store
CC 28/29 Gallary	8 nos 350W LED bay lamps fixed
LC 2	Battery charger panel maintenance was done
LC 5 and LC 6	For HT transformer testing, supply provided for DNW
CC 111,112,203 T/E	Welding JBs installed and supply charged with 63A 4 pole MCB and connectors
S 3	Lower MCC top sheets painting done
SCR 10	LUFF oil level switch fixed and checked. LT resistance box connections tightened
.CC 105.SCR 10	PPM was done
CC 105	ZSS module and probe replaced and tested